ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV

ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1160427

Product: Terminal

Type: EPS 3

Rating: 0,75 - 16 mm2

Ordering firm: Elektro, výrobní družstvo v Bečově nad Teplou
Tovární 128, 364 64 Bečov nad Teplou, Czech Republic

Manufacturer: Elektro, výrobní družstvo v Bečově nad Teplou
Tovární 128, 364 64 Bečov nad Teplou, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 601541-01/01 of: 20.05.2016

A sample of the product was found to be in conformity with:
ČSN EN 60998-1 ed. 2:05 cl. 7, 8, 9, 10, 11, 12, 14, 15, 16, 18

Other data:

The validity of the certificate is limited to: 31.05.2019

elektrotechnický zkušební ústav ezú -1- Pod Lisem 129, 171 02 Praha 8 - Troja

27.05.2016

Prague

Mgr. Miroslav Sedláček
Head of Certification Body

Stamp

CER/1160427

601541-01