ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV

ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1160426

Product: End clamps RSA

Type: RSA L15/L35, RSA L35-2

Rating: -25 °C to +55 °C

Ordering firm: Elektro, výrobní družstvo v Bečově nad Teplou
Tovární 128, 364 64 Bečov nad Teplou, Czech Republic

Manufacturer: Elektro, výrobní družstvo v Bečově nad Teplou
Tovární 128, 364 64 Bečov nad Teplou, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 601539-01/01 of: 20.05.2016

A sample of the product was found to be in conformity with:
ČSN EN 60947-7-1 ed. 3:10 cl. 5.1, 7.1.4, 7.1.5, 8.5,
ČSN EN 60998-1 ed .2:05 cl. 16, 18, 19

Other data:

The validity of the certificate is limited to: 31.05.2019

27.05.2016

Prague

Mgr. Miroslav Sedláček
Head of Certification Body

elektrotechnický zkušební ústav ezú -1- Pod Lisem 129, 171 02 Praha 8 - Troja

Stamp

CER/1160426