

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1230162

Product: Terminal

Type: PS 3, SN 3, SPE 3

Rating: 0,75 - 16 mm², 750 V AC, 830 V DC

Ordering firm: Elektro, výrobní družstvo v Bečově nad Teplou
Tovární 128, 364 64 Bečov nad Teplou, Czech Republic

Manufacturer: Elektro, výrobní družstvo v Bečově nad Teplou
Tovární 128, 364 64 Bečov nad Teplou, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 231012-01/01 of: 27.04.2023

A sample of the product was found to be in conformity with:
ČSN EN 60998-2-1 ed. 2:05, ČSN EN 60998-1 ed. 2:05, ČSN EN 60947-7-1 ed. 3:10

Other data:

The validity of the certificate is limited to: 01.05.2026

02.05.2023

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



231012-01