

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod líssem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1230171

Product: Terminal block with varistor

Type: RSA 4 AV-24, RSA 4 AV-250

Rating: 24 V and 250 V

Ordering firm: Elektro, výrobní družstvo v Bečově nad Teplou
Tovární 128, 364 64 Bečov nad Teplou, Czech Republic

Manufacturer: Elektro, výrobní družstvo v Bečově nad Teplou
Tovární 128, 364 64 Bečov nad Teplou, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 231010-01/01 of: 26.04.2023

A sample of the product was found to be in conformity with:
ČSN EN 60947-7-1 ed. 3:10 cl. 5, 8.3.2, 8.3.3.1, 8.3.3.4, 8.3.3.5, 8.4.3 a), 8.4.5, 8.5

Other data:

The validity of the certificate is limited to: 01.05.2026

02.05.2023

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



231010-01