

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHJECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1250088

Product: Terminal block and accessories

Type: RSA 16A

Rating: 16 mm², U_i 1000 V

Ordering firm: Elektro, výrobní družstvo v Bečově nad Teplou
Tovární 128, 364 64 Bečov nad Teplou, Czech Republic

Manufacturer: Elektro, výrobní družstvo v Bečově nad Teplou
Tovární 128, 364 64 Bečov nad Teplou, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 250370-01/01 of: 25.02.2025

A sample of the product was found to be in conformity with:

ČSN EN 60947-7-1 ed. 3:2010 (idt IEC 60947-7-1:2009),
ČSN EN IEC 60947-1 ed. 5:2025 (idt IEC 60947-1:2020),
TNI 370606

Other data:

The validity of the certificate is limited to: 02.03.2028

03.03.2025

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



250370-01